



Garden State Laboratories, Inc.

Report Date: 03/29/2022

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Kiddie Quarters
1730 Stuyvesant Ave.

Union, NJ 07083

Attention: Valerie Ellington

Client Number: KID07

Laboratory Director:

Sample ID: Lab Sample ID: 220323062-01
Site: 1730 Stuyvesant Ave Union
NJ - Field Blank Collection Date/Time: 03/23/2022 06:30
Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	1.3	0.00100	7E-05	20044	03/29/22 09:44	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/28/22 20:03	

Sample ID: Lab Sample ID: 220323062-02
Site: 1730 Stuyvesant Ave Union
NJ - Kitchen Collection Date/Time: 03/23/2022 06:30
Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.8	5	0.127 mg/l	1.3	0.00500	0.00035	20044	03/29/22 10:29	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/28/22 20:06	

Sample ID: Lab Sample ID: 220323062-03
Site: 1730 Stuyvesant Ave Union
NJ - Girls Bathroom Collection Date/Time: 03/23/2022 06:30
Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.8	1	0.0351 mg/l	1.3	0.00100	7E-05	20044	03/29/22 09:59	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/28/22 20:15	



Sample ID: Lab Sample ID: 220323062-04
 Site: 1730 Stuyvesant Ave Union Collection Date/Time: 03/23/2022 06:30
 NJ - Boys Bathroom
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.8	2	0.0595 mg/l	1.3	0.00200	0.00014	20044	03/29/22 10:33	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/28/22 20:18	

Sample ID: Lab Sample ID: 220323062-05
 Site: 1730 Stuyvesant Ave Union Collection Date/Time: 03/23/2022 06:30
 NJ - Upstairs Staff Bathroom
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.8	5	0.129 mg/l	1.3	0.00500	0.00035	20044	03/29/22 10:37	
Lead, Total Recoverable	EPA 200.9	1	0.00257 mg/l	0.015	0.00100	0.00055	20044	03/28/22 20:21	

Sample ID: Lab Sample ID: 220323062-06
 Site: 1174 Stuyvesant Ave - Field Collection Date/Time: 03/23/2022 07:00
 Blank
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	1.3	0.00100	7E-05	20044	03/29/22 10:10	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/28/22 20:24	

Sample ID: Lab Sample ID: 220323062-07
 Site: 1174 Stuyvesant Ave - Collection Date/Time: 03/23/2022 07:00
 Kitchen
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.8	5	0.139 mg/l	1.3	0.00500	0.00035	20044	03/29/22 10:41	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/28/22 20:27	

Sample ID: Lab Sample ID: 220323062-08
 Site: 1174 Stuyvesant Ave - Collection Date/Time: 03/23/2022 07:00
 Childrens Bathroom
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.8	5	0.137 mg/l	1.3	0.00500	0.00035	20044	03/29/22 10:44	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/28/22 20:35	



*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*



Garden State Laboratories, Inc.